



**ADDENDUM NO. 3**

**0.11 MGD WASTEWATER TREATMENT FACILITY NO. 2-PHASE 1  
WITHIN  
HARRIS COUNTY MUNICIPAL UTILITY DISTRICT NO. 1  
HARRIS COUNTY, TEXAS  
PROJECT NO.: 19900-502-1-STP**

**Date: August 5, 2010**

**VEI Job No: 19900-5021-STP**

**To: All Bidders of Record**

This ADDENDUM is an amendment to the BID DOCUMENTS and TECHNICAL SPECIFICATIONS and shall become part of the AGREEMENT. All bidders shall acknowledge receipt of this ADDENDUM in the space provided on the Bid Proposal. Failure to do so may subject the Bidder to disqualification.

**PROPOSAL**

No changes. Bid date is still Monday August 9, 2010 at 2:30 pm.

**CONTRACT FORMS**

No changes

**CONDITIONS OF THE AGREEMENT**

No changes

## TECHNICAL SPECIFICATIONS

No changes.

## CONSTRUCTION DRAWINGS

Additions and changes have been made to the following sheets:

1. **Sheet 7 of 59:** The elevations are removed and the plan clarified to show the temporary road will be built on existing grade, with bar ditches to handle roadway drainage. A double 30-inch driveway culvert is added at the turn near the detention pond to handle off-site drainage. Use bar ditch excavation to build this area up slightly to take the road over the driveway culverts in a way that sludge trucks can handle.

The revised sheet can be picked up with the addendum or may be downloaded from the Van DeWiele & Vogler, Inc. website.

**END OF ADDENDUM NO. 3**



---

Norman F. Scholes, P.E.  
Senior Project Engineer

;ns  
Enclosure

19900-502-1-stp/docs/addendum No.3/addendum3.doc