

ADDENDUM NO. 1

**0.45 MGD WWTF REHABILITATION
WITHIN RICHEY ROAD MUNICIPAL UTILITY DISTRICT,
HARRIS COUNTY, TEXAS**

Date: September 7, 2010

VEI Job No: 09900-502-4-STP (c&e)

To: All Bidders of Record

This ADDENDUM is an amendment to the BID DOCUMENTS and TECHNICAL SPECIFICATIONS and shall become part of the AGREEMENT. All bidders shall acknowledge receipt of this ADDENDUM in the space provided on the Bid Proposal. Failure to do so may subject the Bidder to disqualification.

BID DATE

Bid opening shall be revised to open bids on **Monday, September 13, 2010 at 11:00 a.m.** at the offices of Van De Wiele & Vogler, Inc., 2925 Briarpark, Suite 275, Houston, TX 77042.

PROPOSAL

No changes to the Bid Proposal.

SPECIFICATIONS

No changes to the Project Specifications.

PLANS

No changes to the Project Plan Set.


PROJECT CLARIFICATION:

1. Dewatering and sludge removal from basins as well as plant shutdown and effluent wet hauling operations shall be the responsibility of the Owner.
2. Pressure washing and basin cleaning is incidental to basin blasting & coating operations.
3. Contractor's Notice to Proceed date & contract time shall not commence until such time as Contractor has mobilized, received and/or ordered all materials needed to complete project & plant has been shutdown and sludge removed.
4. Where a disparity exists between Project Specifications and Bid Proposal in regards to unit quantity measurement and unit pricing, Bid Proposal takes precedence.

5. Where "NEW STAINLESS STEEL DROPS & DIFFUSERS" are denoted in the plans, stainless steel refers to 316SS (Schedule 40) pipe & wide band coarse bubble diffusers to match existing diffusers.
6. Removal of portions of existing plant roof are allowed for construction operations. Should Contractor utilize removal of plant roof for construction operations, he does so at his own risk and cost to perform work is incidental to the contract costs. If roof is removed, it shall be replaced to original or better condition.
7. While contract time is of the essence, it is understood from Pre-Bid Conference comments that a preferred 60-day contract time is not most likely feasible. As such contract time will be left open as a bid item with the understanding that should the contract time bid exceed 90 days, bids may be disqualified and the project re-bid at a later date when time is not such a significant factor.

END OF ADDENDUM NO. 1

**0.45 MGD WWTF REHABILITATION
WITHIN RICHEY ROAD MUNICIPAL UTILITY DISTRICT,
HARRIS COUNTY, TEXAS**



Jerry Hlozek, P.E., CFM
Project Manager
Van De Wiele & Vogler, Inc.
Texas Registered Engineering Firm No. 148

